



**BUREAU  
VERITAS**

# Certificate for the NS protection

**Manufacturer / applicant:** SolarEdge Technologies Ltd.  
1 HaMada Street  
Herzliya 4673335  
Israel

|   |   |
|---|---|
| <b>Type of grid and plant protection:</b> | <b>Integrated NS protection</b>                       |
| <b>Assigned to generation unit type:</b>  | SE5K-RWB48<br>SE7K-RWB48<br>SE8K-RWB48<br>SE10K-RWB48 |

**Firmware version:** DSP 1: 1.20, DSP 2: 2.20

**Connection rule:** VDE-AR-N 4105:2018-11 – Power generation systems connected to the low-voltage distribution network  
Technical minimum requirements for the connection to and parallel operation with low-voltage distribution networks.

**Applicable standards / directives:** DIN VDE V 0124-100 (VDE V 0124-100):2020-06 – Grid integration of power generation systems – low voltage  
Test requirements for power generation units to be connected and operated parallel with the low-voltage distribution networks

The above-mentioned grid and plant protection has been tested and certified according to the test guideline VDE 0124-100. The electrical properties required in the connection rule are satisfied.

- Setting values and disconnect times
- Properly functioning functional chain "NS protection – interface switch"
- Technical requirements of the switching device
- Integrated interface switch that can also be used in conjunction with a central interface protection relay (VDE-AR-N 4105:2018-11 §6.4.1)
- Active detection of unintended islanding
- Single-fault tolerance

The certificate contains the following information:

- Technical specifications of the NS protection and corresponding power generation types
- Setting values of the protection functions
- Trip values of the protection functions

**Report number:** 22TH0188-VDE-0124-100\_0

**Certification program:** NSOP-0032-DEU-ZE-V01

**Certificate number:** U22-0729

**Date of issue:** 2022-12-02



Certification body of Bureau Veritas Consumer Products Services Germany GmbH Accredited according to DIN EN ISO/IEC 17065

Testing laboratory accredited according to DIN EN ISO/IEC 17025

A partial representation of the certificate requires the written permission of Bureau Veritas Consumer Products Services Germany GmbH



BUREAU  
VERITAS

## Annex to the Certificate for the NS-protection No. U22-0729

### E.6 and E.7 Requirements for the test report for the NS protection

Extract from test report for NS protection  
"Determination of electrical properties"

Nr. 22TH0188-VDE-0124-100\_0

## NS protection as integrated NS protection

|   |  |
|---|--|
| <b>Manufacturer / applicant:</b>          | SolarEdge Technologies Ltd.<br>1 HaMada Street<br>Herzliya 4673335<br>Israel |
| <b>Type of grid and plant protection:</b> | integrated NS protection   |
| <b>Assigned to generation unit type:</b>  | SE5K-RWB48<br>SE7K-RWB48<br>SE8K-RWB48<br>SE10K-RWB48                        |
| <b>Firmware version:</b>                  | DSP 1: 1.20, DSP 2: 2.20   |
| <b>Integrated interface switch:</b>       | Type of switching equipment 1: Relay<br>Type of switching equipment 2: Relay |
| <b>Measurement period:</b>                | 2022-05-01 – 2022-11-09  |

### Inverter

| Protection function               | Setting value | Trip value | Disconnection time <sup>a</sup> |
|-----------------------------------|---------------|------------|---------------------------------|
| Voltage drop protection U <       | 184,0 V       | 183,3 V    | 3 s                             |
| Voltage drop protection U <<      | 103,5 V       | 102,7 V    | 0,300 s                         |
| Rise-in-voltage protection U >    | 253,0 V       | --         | 0,100 s <sup>b</sup>            |
| Rise-in-voltage protection U >>   | 287,5 V       | 287,1 V    | 0,150 s                         |
| Frequency decrease protection f < | 47,50 Hz      | 47,50 Hz   | 0,150 s                         |
| Frequency increase protection f > | 51,50 Hz      | 51,50 Hz   | 0,150 s                         |

<sup>a</sup> proper time of interface switch 10 ms

<sup>b</sup> longest disconnection of the rise-in-voltage protection as a moving 10-minute-average, tested according clause 5.5.7 Protection devices and protection settings of VDE 0124-100

The disconnect time (sum of trip time of grid and plant protection and delay time of interface switch) must not exceed 200 ms.

A check of the overall functional chain "NS protection – interface switch" resulted in a successful disconnection.

The above-mentioned grid and plant protection with the assigned power generation units has met the requirements for islanding detection with the help of the active method (resonant circuit test).

The above-mentioned NS protection meet the requirements for synchronization.