

CERTIFICATE of Conformity



Registration No.: AK 50556433 0001

Report No.: 50256527 003

Holder: GoodWe Technologies Co., Ltd.
No.90 Zijin Rd., New District
215011 Suzhou
P.R. China

Product: PV-Inverter
Hybrid Inverter

Identification: Type Designation: GW10K-ET GW8K-ET GW6.5K-ET GW5K-ET
GW5KN-ET GW6.5KN-ET GW8KN-ET GW10KN-ET
GW5K-BT GW6K-BT GW8K-BT GW10K-BT
Serial Number : Engineering Samples
Firmware Version: 090922
Continued on page 0002

Tested acc. to: UTE C15-712-1/07.13
DIN V VDE V 0126-1-1:2006+A1

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Certification Body

Date 29.08.2022



Weichun Li

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

CERTIFICATE of Conformity



Registration No.: AK 50556433 0002

Report No.: 50256527 003

Holder: **GoodWe Technologies Co., Ltd.**
No.90 Zijin Rd., New District
215011 Suzhou
P.R. China

Product: **PV-Inverter**
Hybrid Inverter

Identification: As page 0001 continuation
Remark : The reference standard of VFR 2019,
Enedis-FOR-RES_18E: 2019, SEI REF 04 V7/
Category 3 and EDT V1 were considered,
refer to test report 50256527 003 for
details.

Tested acc. to: UTE C15-712-1/07.13
DIN V VDE V 0126-1-1:2006+A1

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Certification Body

Date 29.08.2022




Weichun Li

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

Vérification de Conformité

Fabricant: <i>Manufacturer</i>	Goodwe Technologies Co.,Ltd. No.90 Zijin Rd., New District, 215011 Suzhou P.R. China
Type de produit: <i>Type of product</i>	Hybrid Inverter
Modèle: <i>Model</i>	GW10K-ET, GW8K-ET, GW6.5K-ET, GW5K-ET, GW10KN-ET, GW8KN-ET, GW6.5KN-ET, GW5KN-ET, GW5K-BT, GW6K-BT, GW8K-BT, GW10K-BT
Version du firmware: <i>Firmware version</i>	090922
Norme: <i>Standard</i>	UTE C15-712-1/ 07.13 DIN V VDE V 0126-1-1 :2006+A1 VFR 2019 Enedis-FOR-RES_18E : 2019 SEI REF 04 V7/Category 3 EDT V1
Date d'émission: <i>Date of issue</i>	29.08.2022

La vérification de conformité se réfère au produit mentionné ci-dessus. Il s'agit de vérifier que le spécimen est conforme à l'exigence d'évaluation mentionnée ci-dessus. Cette vérification n'implique pas une évaluation de la production du produit et ne permet pas l'utilisation d'une marque de conformité TÜV Rheinland. Cette vérification de conformité repose sur le certificat no. AK 50556433 0001-0002 et le rapport d'essai no. 50256527 003.

The verification of conformity refers to the above mentioned product. This is to verify that the specimen is in conformity with the assessment requirement mentioned above. This verification does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity. This verification of conformity bases on the certificate no. AK 50556433 0001-0002 and test report no. 50256527 003.